



BOROUGH OF DUNDEE

MUNISIPALITEIT

TOWN CLERKS DEPARTMENT
STADSKLERK SE DEPARTAMENT

TEL. 22121
REF./ VERW. _____

P. O. BOX / POSBUS 76
DUNDEE, 3000

YOUR REF. Q-D/87/84[2]
U VERW. _____

ENQUIRIES P.R. Maple
NAVRAE _____

17 July

The Manager
Dundee Office Machines (Pty.) Ltd.
P.O. Box 311
Dundee
3000

Dear Sir

SURVEY - SOLAR FILM

I am pleased to be able to report back regarding the survey on your Solar film product. This was carried out in the municipal building in rooms 68 & 69 (without and with film respectively). The method used for measuring the penetration of heat by the sun was by placing two identical "Barigo Maxra" thermometers 23cm from the windows - with two readings taken per day.

SURVEY RESULTS

ROOM 69(with film)	WEATHER	ROOM 68(Without film)	PERCENTAGE HOTTER
1pm 26°C	Sunny/still	42°C	61,54%
2:45pm 28°C		39°C	39,29%
1pm 27°C	Cold wind	31°C	14,82%
2:45pm 21°C		24°C	14,29%
1pm 25°C	Sunny/still	41°C	64%
2:45pm 27°C		39°C	44,45%
1pm 24°C	Sunny/still	39°C	62,5%
2:45pm 26°C		35°C	34,65%
1pm 25°C	Sunny/still	38°C	52%
1pm 25°C	Sunny/still	40°C	60%

READINGS FOR THE LAST TWO DAYS WERE NOT TAKEN INTO ACCOUNT AS THE AIR-CONS WERE RUNNING - REFER HERE TO pm READINGS ONLY

Summer readings would most certainly be more effective

Yours faithfully



O.A. CLASSEN
TOWN CLERK